



LPG TANK INSTALLATIONS

Installations of all portable or underground LPG tanks will conform to the following requirements:

- The 2006 International Fire Code
- The 2006 International Fuel Gas Code
- The 2006 International Plumbing Code
- The 2008 edition of NFPA 58 – Liquefied Petroleum Gas Code
- Any other nationally recognized standards or codes as deemed necessary and appropriate by the Town of Buckeye.
- Tank placement shall NOT be any closer than five (5) feet to the property line.
- Portable LPG tank installations shall be placed on a concrete surface sufficient to support the full weight of the tank and elevated to protect the base of the tank from moisture.
- Portable tanks will be secured to a free standing support. The support will be constructed of steel, coated to protect it from the elements. Attaching devices will be constructed of chain and will be securely fastened on both sides. The chain will be of adequate size to support the full weight of the cylinder. The metal support will be anchored in concrete at a depth sufficient to support the full weight of the tank. Tanks shall NOT be secured to walls, fences or structures.
- Underground tanks shall not be buried until inspected and approved for burial by the Town of Buckeye Fire Department.
- Tanks subject to vehicular traffic will be protected in accordance with the Fire Code or as deemed necessary by the Town of Buckeye Fire Department.
- All installations will require plan submittal and the issuance of a building permit from the Town of Buckeye prior to installation.
- Any questions feel free to call 623-349-6700.

Bob Costello,
Fire Chief